GOVERNMENT OF PUNJAB
DEPARTMENT OF LOCAL GOVERNMENT
(LOCAL GOVERNMENT-4 BRANCH)
(PUNJAB MUNICIPAL BHAWAN, PLOT NO.3, SECTOR 35 A, CHANDIGARH)

Notification

The 28 June, 2019

No.5/177/2014(11)-1LG4/ 1978-A..... In pursuance of the recommendations of the 14th Finance Commission of Government of India, the Governor of Punjab is pleased to notify the Service Level Benchmarks, as per the Schedule given below, to achieve the targets for improvement in the four service sectors, namely, (i) Water Supply, (ii) Sewage Management (Sewerage and Sanitation), (iii) Storm Water Drainage, and (iv) Solid Waste Management, in all the Municipal Corporations, Municipal Councils and Nagar Panchayats in the State of Punjab.

Scanned by CamScanner

Solid Waste Management Indicator

		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
1.	Amritsar (MC)	88	100	95	100	10	90	15	50	80	95	95	100	5	35	50	95
2.	Phagwara (MC)	100	100	91	100	30	100	30	80	98	100	100	100	30	100	30	90
3.	Hoshiarpur (MC)	100	100	100	100	100	100	80	100	100	100	90	100	100	100	90	100
4.	Moga (MC)	85	100	85	100	40	80	40	80	70	90	70	90	0	50	0	50
5.	Pathankot (MC)	80	100	95	100	20	100	0	60	70	100	100	100	0	60	0	60
6.	Bathinda (MC)	90	100	100	100	80	100	100	100	100	100	70	90	0	100	80	90
7.	Mohali (MC)	100	100	100	100	24	50	24	50	70	90	70	85	0	0	80	90
8.	Patiala (MC)	98	100	95	100	18	70	2	70	92	100	40	100	77	100	3	90
9.	Jalandhar (MC)	90	100	90	100	20	60	50	80	70	90	80	90	20	30	20	60
10.	Ludhiana (MC)	85	95	100	100	30	80	50	80	70	90	80	90	20	30	50	60
				DDR Amritsar													
1	Ramdass	85	90	85	90	10	20	10	20	0	10	82	90	20	70	45	75
2)	Dera baba nanak	80	100	80	100	0	10	0	30	0	10	30	50	30	50	50	80

				Solid Waste Management Indicator															
		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
3)	Dhariwal	70	90	70	90	62	91	28	40	24	48	72	90	0	0	0	70
4)	Rayya	80	90	100	100	10	70	20	50	10	30	90	100	0	40	80	90
5)	Shri Hargobind pur	40	70	60	80	42	71	22	34	14	38	62	80	0	0	0	60
6)	Majitha	65	85	75	100	40	60	40	60	50	80	75	95	70	90	70	85
7)	Quadian	90	100	90	100	65	100	35	45	30	60	90	100	0	0	0	80
8)	Raja Sansi	80	85	100	100	10	70	40	60	10	30	90	100	0	40	80	90
9)	Dina nagar	90	100	100	100	10	40	20	40	10	40	80	90	0	0	80	90
10)	Bhikhiwind	80	90	80	90	10	50	20	50	10	30	90	100	50	60	50	80
11)	Fatehgarh churian	90	95	90	95	10	15	20	25	10	15	90	95	90	100	80	85
12)	Khemkaran	70	80	60	80	0	10	0	10	0	20	0	10	80	90	50	80
13)	Ajnala	85	95	85	95	10	30	10	30	0	10	70	90	30	70	40	70
14)	Jandiala guru	72	80	65	100	0	10	0	20	0	10	72	80	53	80	0	0
15)	Sujanpur	80	90	90	100	30	70	20	30	30	60	90	100	0	0	80	90

				Solid Waste Management Indicator													
		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
16)	Patti	80	100	80	100	35	100	40	80	35	100	70	80	0	100	0	90
17)	Tarn taran	70	80	65	100	10	40	20	60	0	30	20	80	20	70	0	30
18)	Gurdaspur	80	100	80	100	50	100	40	70	60	90	90	100	60	80	60	90
19)	Batala	75	100	65	100	10	100	20	80	0	20	80	80	15	60	55	90
20)	Narot Jamal Singh	60	70	60	70	20	70	20	30	0	70	0	100	0	0	0	60
				DDR Bathinda													
1)	Boha	69	100	65	100	46	100	36	80	40	100	0	90	0	100	0	90
2)	Rampura	18	100	15	100	10	100	8	80	9	100	0	90	0	100	0	90
3)	Ballianwali	36	100	33	100	20	100	16	80	18	100	0	90	0	100	0	90
4)	Chauke	18	100	15	100	10	100	8	80	9	100	0	90	0	100	0	90
5)	Maluka	100	100	95	100	44	100	56	80	60	100	64	90	0	100	0	90
6)	Nathana	33	100	30	100	28	100	22	80	24	100	0	90	0	100	0	90
7)	Lehra mohabbat	50	100	45	100	20	100	16	80	18	100	0	90	0	100	0	90
8)	Bariwala	73	100	70	100	0	100	0	80	0	100	76	90	0	100	0	90

Solid Waste Management Indicator

		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
9)	Kotha guru	73	100	69	100	0	100	0	80	0	100	0	90	0	100	0	90
10)	Kot Shamir	57	69	100	100	67	83	33	50	67	50	81	100	0	100	0	100
11)	Sangat mandi	56	100	50	100	11	100	8	80	9	100	0	90	0	100	0	90
12)	Bhai rupa	50	100	48	100	23	100	18	80	20	100	0	90	0	100	0	90
13)	Joga	46	100	44	100	45	100	36	80	40	100	14	90	0	100	0	90
14)	Kotfatta	100	100	95	100	95	100	76	80	85	100	55	90	0	100	0	90
15)	Mandi kalan	100	100	97	100	54	100	43	80	50	100	63	90	0	100	0	90
16)	Mehraj	20	36	100	100	17	33	50	60	33	57	74	100	0	30	0	84
17)	Bhagta bhai ka	64	100	60	100	36	100	28	80	32	100	0	90	0	100	0	90
18)	Bhucho mandi	100	100	92	100	0	100	0	80	0	100	0	90	0	100	0	90
19)	Bareta	62	100	58	100	53	100	42	80	48	100	74	90	0	100	0	90
20)	Raman	59	83	100	100	3	14	1	7	63	46	49	100	0	100	0.00	85
21)	Bhikhi	60	100	80	100	60	100	50	100	20	80	90	100	0	50	60	100

Solid Waste Management Indicator

		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
22)	Goniana	100	100	90	100	30	100	24	80	26	100	66	90	0	100	0	90
23)	Gidderbaha	60	100	50	100	26	100	21	80	22	100	58	90	0	100	0	90
24)	Rampura phul	76	100	65	100	0	100	0	80	0	100	0	90	0	100	0	90
25)	Sardulgarh	100	100	90	100	84	100	67	80	75	100	89	90	0	100	0	90
26)	Maur	35	100	30	100	0	100	0	80	0	100	10	90	0	100	0	90
27)	Budhlada	50	100	45	100	36	100	28	80	30	100	18	90	0	100	0	90
28)	Talwandi saboo	52	80	42	0	25	80	15	60	42	100	87	95	0	100	0	90
29)	Malout	70	100	60	100	10	100	8	80	9	100	0	90	0	100	0	90
30)	Muktsar sahib	84	100	77	100	25	100	20	80	22	100	66	90	0	100	0	90
31)	Mansa	70	100	60	100	37	100	29	80	34	100	0	90	0	100	0	90
				DDR Ferozepur													
1	Arniwalasheksubhan	80	90	90	100	10	80	20	80	10	80	60	90	40	60	80	90
2)	Kotisse khan	85	100	80	100	10	80	20	80	10	80	60	90	60	80	60	80
3)	Mallanwalakhas	85	90	80	100	10	80	0	60	0	60	80	90	40	60	80	90

				Solid Waste Management Indicator													
		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
4)	Mamdot	85	90	90	100	10	80	20	80	10	80	60	80	40	60	70	80
5)	Mudki	80	100	90	100	10	80	20	80	10	80	70	90	60	80	70	90
6)	Nihalsinghwala	90	100	90	100	10	80	20	80	10	80	60	90	40	60	70	90
7)	Guru har sahai	80	100	90	100	10	80	20	80	10	80	70	90	60	80	90	90
8)	Talwandibhai	90	100	80	100	60	90	20	80	10	60	90	90	60	80	80	90
9)	Makhu	80	90	90	100	10	60	20	60	10	60	70	90	40	60	70	90
10)	Badhnikalan	80	90	80	90	10	80	20	80	10	60	60	80	40	60	60	80
11)	Dharamkot	90	100	90	100	10	80	20	80	10	80	90	90	50	100	80	90
12)	Baghapuran	80	90	90	100	10	80	20	80	10	80	90	90	60	80	70	80
13)	Jaitu	85	100	95	100	10	80	20	80	10	80	80	90	60	80	70	90
14)	Jalalabad	80	90	90	100	10	80	20	60	10	80	90	90	80	90	80	90
15)	Zira	80	90	90	100	10	80	20	80	10	80	90	90	60	80	80	90
16)	Abohar	80	90	90	100	10	80	20	80	10	80	90	90	60	80	70	90
17)	Faridkot	90	100	90	100	10	80	20	80	10	80	90	90	72	100	80	90

				Solid Waste Management Indicator													
		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
18)	Fazilka	90	100	90	100	10	80	20	80	10	80	90	90	60	80	70	90
19)	Kotkapura	90	100	90	100	10	80	20	80	10	80	90	90	40	60	80	90
20)	Ferozepur	85	100	100	100	10	90	20	80	10	100	90	90	60	80	80	90
21)	Fatehgarh Panjtoor	80	90	80	90	10	80	20	80	10	70	90	90	40	60	80	90
				DDR Jalandhar													
1)	Talwara	85	95	85	100	20	50	15	25	0	10	85	95	0	100	70	80
2)	Gardhiwala	70	100	80	100	0	100	0	80	0	50	70	80	0	40	30	60
3)	Shamchurasi	100	100	100	100	60	100	100	100	50	100	100	100	0	100	0	100
4)	Bilga	80	100	90	100	55	90	0	20	0	10	50	70	0	20	25	50
5)	Hariana	90	100	80	100	30	100	0	20	0	8	50	80	0	15	0	20
6)	Nadala	30	50	80	85	20	60	60	80	10	25	60	65	0	20	20	30
7)	Dhilwan	80	90	80	90	70	80	20	40	20	30	80	90	65	70	60	70
8)	Lohian khas	80	100	80	100	0	70	0	100	0	100	82	100	0	100	40	100
9)	Alawalpur	95	100	95	96	32	50	25	35	10	20	95	96	0	50	0	50

				Solid Waste Management Indicator															
		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
10)	Mahetpur	80	100	80	100	50	100	0	100	30	100	87	100	30	85	40	70
11)	Begowal	80	90	80	90	0	10	0	20	0	10	95	100	40	80	40	80
12)	Mahilpur	80	90	100	100	10	50	20	40	10	20	90	90	0	50	80	85
13)	Bhulath	70	90	75	90	60	80	80	90	0	0	40	60	40	50	40	50
14)	Mukerian	70	100	80	100	60	100	80	100	0	50	70	80	84	90	40	70
15)	Rahon	80	90	80	85	0	0	15	25	10	12	95	100	0	80	70	75
16)	Nur mahal	100	100	90	100	90	100	0	30	0	10	85	90	0	30	0	40
17)	Shahkot	75	90	85	95	0	0	0	20	0	10	92	95	**0**	**20**	40	70
18)	Bhogpur	100	100	100	100	50	70	50	80	50	100	100	100	0	50	0	50
19)	Garhshankar	70	90	80	100	85	100	70	100	0	0	50	80	30	35	0	50
20)	Goraya	90	100	85	100	45	100	0	20	0	10	50	80	0	20	0	30
21)	Sultanpur lodhi	80	85	90	95	0	60	20	25	10	12	90	90	80	80	0	0
22)	Adampur	85	90	100	100	0	50	20	25	10	15	95	97	95	97	80	82
23)	Banga	70	80	80	90	0	60	0	80	0	20	90	100	0	10	50	55

				Solid Waste Management Indicator													
		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
24)	Balachaur	80	85	90	95	10	15	20	25	10	15	95	100	0	10	60	70
25)	Dasuya	90	100	100	100	100	100	100	100	0	0	80	90	0	0	45	50
26)	Urmur tanda	80	100	80	100	50	100	10	40	20	30	80	90	0	20	25	40
27)	Kartarpur	90	100	100	100	10	70	20	50	10	60	90	100	0	40	70	90
28)	Nawanshahr	80	90	90	100	10	50	40	50	10	20	98	90	50	70	70	75
29)	Nakodar	100	100	100	100	70	100	0	80	0	100	80	100	0	100	0	100
30)	Phillaur	90	100	83	100	60	100	0	25	0	15	60	82	0	22	0	35
31)	Kapurthala	90	100	90	100	55	100	10	40	80	100	75	90	0	50	80	90
		DDR Ludhiana															
1.	Kiratpur Sahib	100	100	100	100	100	100	20	40	0	50	80	80	0	30	0	50
2.	Payal	100	100	100	100	0	30	100	100	20	25	95	100	0	20	0	20
3.	Amloh	80	95	80	98	60	70	60	70	40	80	70	80	0	0	0	0
4.	Morinda	90	100	90	100	40	100	30	100	45	60	90	100	30	60	0	30

Solid Waste Management Indicator

		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
5.	Sirhind Fatehgarh Sahib	90	95	90	95	10	20	20	50	10	20	80	85	50	60	60	70
6.	Ropar	90	100	90	100	85	100	90	100	60	80	80	90	50	80	50	80
7.	Bassi pathana	85	90	80	90	0	10	0	20	0	10	85	90	0	25	35	65
8.	Anandpur sahib	80	95	70	100	80	100	80	100	40	50	30	60	20	40	30	40
9.	Maloud	85	95	90	100	40	80	0	20	0	50	90	100	5	50	35	90
10.	Chamkaur Sahib	75	95	80	100	0	20	0	30	0	20	100	100	0	20	100	100
11.	Khamano	80	90	80	100	50	80	20	80	50	80	80	80	50	80	60	70
12.	Mullanpur	90	95	100	100	10	20	20	30	10	20	90	100	0	0	80	90
13.	Nangal	90	100	90	100	90	100	70	80	90	100	70	80	80	100	50	90
14.	Sahnewal	90	100	100	100	80	100	20	25	10	25	90	100	70	90	80	90
15.	Machhiwara	100	100	100	100	100	100	80	90	45	60	90	100	20	50	20	50
16.	Raikot	100	100	90		10	20	20		10	10	90	100	0	90	70	70
17.	Doraha			80	100	80	100	65	80	70	100	70	80	0	90	0	90
18.	Samrala	90	100	90	100	70	100	60	80	55	80	90	90	90	100	50	70

				Solid Waste Management Indicator													
		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
19.	Jagraon	90	100	90	100	30	100	20	50	15	90	50	80	40	100	0	50
20.	Mandi Gobindgarh	95	100	100	100	40	100	70	80	40	100	80	90	0	100	0	100
21.	Khanna	70	80	75	100	80	100	0	10	20	60	0	18	40	70	40	70
		DDR Patiala															
1)	Amargarh	85	90	80	90	10	20	30	40	10	20	85	90	25	100	50	60
2)	Dirba	90	100	73	90	50	75	60	80	55	75	80	100	0	20	0	0
3)	Ghanaur	73	80	100	100	32	100	20	80	27	100	80	90	0	50	0	0
4)	Bhadson	81	100	100	100	68	100	32	80	35	100	97	100	15	50	5	50
5)	Ghagga	100	100	100	100	45	100	50	80	35	100	80	90	0	100	0	90
6)	Handiaya	75	100	73	100	75	100	75	100	73	100	75	100	72	100	79	100
7)	Cheema	90	100	100	100	100	100	80	90	0	100	80	90	60	80	60	90
8)	Khanauri	90	90	80	100	10	20	0	20	0	10	90	90	0	50	50	90
9)	Longowal	80	90	70	100	80	100	70	80	0	90	60	80	50	65	50	65

Solid Waste Management Indicator

		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
10)	Moonak	95	100	100	100	75	100	40	80	40	100	100	100	20	50	10	50
11)	Sanaur	80	100	96	100	65	100	65	100	70	100	94	100	0	50	0	90
12)	Bhadaur	80	100	70	100	30	100	70	90	0	100	80	90	60	80	60	90
13)	Bhawanigarh	100	100	100	100	100	100	100	100	100	100	100	100	0	40	0	50
14)	Lehragaga	85	90	85	90	100	100	100	100	0	80	60	70	0	10	50	50
15)	Patran	90	100	73	90	60	90	60	80	55	75	80	100	0	20	0	10
16)	Dhanaul	95	100	80	100	50	100	70	100	70	100	80	100	72	100	75	100
17)	Kurali	88	100	67	100	52	100	20	80	0	100	87	90	20	50	0	100
18)	Tapa	75	100	80	100	60	100	80	90	0	100	80	90	60	80	60	90
19)	Ahmedgarh	80	100	82	100	40	100	55	75	55	75	90	100	0	50	0	50
20)	Lalru	50	80	100	100	100	100	40	60	20	50	90	100	0	50	0	50
21)	Samana	90	100	95	100	50	100	65	100	60	100	90	100	0	100	0	100
22)	Banur	66	80	26	40	61	70	60	80	67	80	80	100	0	50	0	50
23)	Dhuri	80	95	90	95	85	95	80	100	90	100	100	100	0	30	0	40

				Solid Waste Management Indicator													
		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
24)	Derabassi	80	100	100	100	24	100	0	100	100	100	95	100	0	100	0	100
25)	Naya gaon	70	100	100	100	10	70	10	70	0	100	70	70	20	50	0	100
26)	Sunam	90	100	73	90	50	75	60	80	55	75	80	100	0	20	0	50
27)	Nabha	90	100	100	100	15	100	65	80	40	100	80	90	0	100	0	100
28)	Sangrur	80	95	95	100	35	50	10	25	0	0	90	100	50	100	0	0
29)	Zirakpur	95	100	90	100	85	100	80	85	80	90	80	95	70	90	80	85
30)	Rajpura	82.3	100	92	100	62	100	67	80	75	100	78	90	10	50	70	90

				Solid Waste Management Indicator													
		Household level coverage of SWM services		Efficiency of collection of MSW		Extent to segregation of solid waste		Extent of MSW recovery		Extent of scientific disposal of MSW		Efficiency in redressal of customer complaints		Extent of cost recovery in SWM services		Efficiency in collection of SWM Charges	
	Formula	(KE*100/(XE+XT)		(LO*100/(KL)		(LP+LQ)*100/LO)		(MF*100/(LO)		(MG*100/(LO)		(MJ*100/(MI)		(NA*100/(MR)		(NC*100/(NA)	
	Benchmark	100%		100%		100%		80%		100%		90%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
31)	Barnala	95	100	100	100	60	100	80	100	80	100	99	100	82	100	85	100
32)	Kharar	85	95	85	95	85	100	85	85	85	95	75	85	80	100	75	85
33)	Malerkotla	95	100	95	100	35	100	60	80	35	100	70	90	0	100	0	100

				Sewerage Management Indicators																	
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
1.	Amritsar (MC)	70	90	80	95	60	70	60	85	100	100	0	10	100	100	15	45	60	70
2.	Phagwara (MC)	65	80	65	80	85	90	100	100	100	100	20	25	85	90	95	100	85	95
3.	Hoshiarpur (MC)	90	100	91	100	80	100	100	100	100	100	0	10	80	100	50	60	70	75
4.	Moga (MC)	26.08	41	26	85	55	60	80	100	100	100	0	10	80	90	30	40	40	60
5.	Pathankot (MC)	70	90	70	90	40	90	90	100	90	95	0	10	70	80	35	50	50	70
6.	Bathinda (MC)	85	100	80	100	46	90	100	100	90	100	0	20	70	80	45	50	60	75
7.	Mohali (MC)	93	100	100	100	93	100	100	100	90	100	0	20	70	80	50	60	65	75
8.	Patiala (MC)	80	100	98	100	49	100	80	100	95	100	20	30	80	90	100	100	80	100
9.	Jalandhar (MC)	99.5	100	58.3	70	78.3	100	80	100	100	100	3	8	70	75	40	60	83	85
10.	Ludhiana (MC)	99	100	100	100	90	100	90	100	100	100	0	10	100	100	26	50	87	90
				DDR Amritsar															

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
1)	Ramdass	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2)	Dera baba nanak	90	95	75	85	70	90	0	100	70	100	0	10	100	100	0	30	0	45
3)	Dhariwal	20	40	40	100	90	100	0	0	0	0	0	0	90	100	80	100	90	100
4)	Rayya	80	90	15	100	0	90	0	5 MLD	0	100	0	15	70	80	0	100	0	95
5)	Shri Hargobind pur	25	40	98	100	100	100	100	100	100	100	20	20	75	80	75	80	83	90
6)	Majitha	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
7)	Quadian	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8)	Raja Sansi	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
9)	Dina nagar	20	40	40	100	90	100	0	0	0	0	0	0	90	100	80	100	90	100
10)	Bhikhiwind	60	70	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
11)	Fatehgarh churian	30	50	80	100	80	100	0	0	0	0	0	0	75	80	65	80	72	90
12)	Khemkaran	15	50	80	80	90	100	0	0	0	0	0	0	90	100	70	80	70	90

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
13)	Ajnala	0	0	70	85	90	100	0	0	0	0	0	0	90	100	30	90	70	80
14)	Jandiala Guru	0	0	30	45	90	80	0	0	0	0	0	0	90	100	0	0	0	80
15)	Sujanpur	70	90	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
16)	Patti	90	100	90	100	0	0	0	0	0	0	0	0	70	80	100	100	25	90
17)	Tarn taran	90	95	75	90	20	100	20	100	20	100	0	100	10	80	20	70	40	90
18)	Gurdaspur	90	95	75	85	70	90	0	100	70	100	0	10	100	100	0	30	0	45
19)	Batala	44	60	55	90	65	90	0	0	0	0	0	0	70	80	55	65	55	70
20)	Narot Jamal Singh	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
				DDR Bathinda															
1)	Boha	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2)	Rampura	90	100	91	100	80	100	100	100	100	100	0	10	80	100	50	60	70	75
3)	Ballianwali	26.08	41	26	85	55	60	80	100	100	100	0	10	80	90	30	40	40	60
4)	Chauke	70	90	70	90	40	90	90	100	90	95	0	10	70	80	35	50	50	70

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
5)	Maluka	85	100	80	100	46	90	100	100	90	100	0	20	70	80	45	50	60	75
6)	Nathana	93	100	100	100	93	100	100	100	90	100	0	20	70	80	50	60	65	75
7)	Lehra mohabbat	80	100	98	100	49	100	80	100	95	100	20	30	80	90	100	100	80	100
8)	Bariwala	99.5	100	58.3	70	78.3	100	80	100	100	100	3	8	70	75	40	60	83	85
9)	Kotha guru	99	100	100	100	90	100	90	100	100	100	0	10	100	100	26	50	87	90
10)	Kot Shamir	60	75	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
11)	Sangat mandi	50	75	80	90	90	95	55	75	55	80	10	25	80	85	50	75	65	80
12)	Bhai rupa	60	80	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
13)	Joga	60	80	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
14)	Kotfatta	70	90	95	98	80	85	80	85	80	85	10	16	70	80	40	50	40	50
15)	Mandi kalan	60	75	NE	NE	0	0	0	NE	0	90	0	0	0	NE	0	NE	0	NE
16)	Mehraj	75	80	50	60	0	0	0	0	0	0	0	0	30	80	20	40	50	60
17)	Bhagta bhai ka	60	75	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
18)	Bhucho mandi	85	90	92	95	80	85	80	90	75	85	5	10	70	80	55	70	50	65
19)	Bareta	95	100	90	100	100	100	90	100	90	100	30	20	75	80	50	70	70	90
20)	Raman	60	75	99	99	95	96	--	--	--	--	--	--	78	85	50	75	65	75
21)	Bhikhi	90	100	90	100	100	100	100	100	85	100	30	20	75	80	70	100	72	90
22)	Goniana	80	90	95	98	70	80	60	75	75	85	5	10	70	80	8	15	70	75
23)	Gidderbaha	70	90	95	98	75	85	70	80	75	90	0	10	70	80	45	70	50	75
24)	Rampura phul	65	80	85	95	75	90	80	100	75	90	0	10	65	75	45	70	50	75
25)	Sardulgarh	98	100	97	99	100	100	98	100	96	100	70	85	75	85	50	70	70	90
26)	Maur	23	50	95	96	75	80	80	90	90	95	20	25	75	85	65	75	50	75
27)	Budhlada	98	100	95	100	100	100	100	100	100	100	20	100	76	80	60	70	67	75
28)	Talwandi saboo	55	75	99	99	95	98	60	80	75	90	12	25	80	90	50	75	50	70
29)	Malout	80	90	96	98	70	80	75	90	75	90	5	10	70	70	45	70	50	75
30)	Muktsar sahib	65	85	60	80	70	100	80	100	75	90	0	10	65	75	30	40	40	50

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
31)	Mansa	98	100	97	99	100	100	98	100	98	100	20	20	72	80	50	70	70	90
				DDR Ferozepur															
1	Arniwalasheksubhan	10	30	20	60	0	0	0	0	0	0	0	0	10	80	20	30	30	50
2)	Kotisse khan	90	95	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
3)	Mallanwalakhas	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
4)	Mamdot	70	100	0	80	0	0	0	90	0	95	0	20	10	80	0	30	0	50
5)	Mudki	80	95	NE	NE	0	0	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
6)	Nihalsinghwala	60	70	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
7)	Guru har sahai	85	100	50	80	0	0	0	0	0	0	0	0	65	80	30	40	60	70
8)	Talwandibhai	90	100	85	100	80	90	100	100	100	100	-	20	70	80	50	70	70	80
9)	Makhu	98	100	0	50	0	50	0	90	0	80	0	0	20	80	0	40	0	70
10)	Badhnikalan	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
11)	Dharamkot	90	100	40	100	0	80	0	95	0	90	0	0	60	80	30	40	60	70

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
12)	Baghapuran	85	90	75	80	0	80	0	90	0	100	0	0	65	80	20	30	50	60
13)	Jaitu	70	90	70	100	75	90	-	100	-	100	-	15	75	90	40	60	70	80
14)	Jalalabad	90	100	85	90	80	90	80	90	90	95	0	15	70	80	10	30	20	30
15)	Zira	90	100	70	90	50	90	80	90	90	100	0	10	65	80	10	20	45	65
16)	Abohar	55	85	65	100	80	100	100	100	100	100	0	0	80	80	55	80	65	80
17)	Faridkot	60	85	60	80	50	80	-	0	-	0	-	0	60	80	50	70	70	80
18)	Fazilka	95	100	80	100	70	90	70	100	70	100	0	10	60	80	20	40	25	60
19)	Kotkapura	70	90	60	95	75	90	-	100	-	100	-	15	70	80	50	65	60	75
20)	Ferozepur	75	90	90	100	79	90	0	100	0	100	0	100	75	80	29	35	98	100
21)	Fatehgarh Panjtoor	10	30	20	60	0	0	0	0	0	0	0	0	10	80	20	30	30	50
				DDR Jalandhar															
1)	Talwara	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
2)	Gardhiwala	60	90	35	80	60	80	0	0	0	0	0	0	60	80	0	20	70	90

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
3)	Shamchurasi	90	100	90	100	80	100	100	100	100	100	0	20	100	100	57	100	65	100
4)	Bilga	Not Applicable due to no sewerage connection																	
5)	Hariana	40	80	20	70	0	0	0	0	0	0	0	0	50	70	20	30	30	50
6)	Nadala	Not Applicable due to no sewerage connection																	
7)	Dhilwan	90	100	60	80	0	0	0	0	0	0	0	0	70	80	20	40	40	60
8)	Lohian khas	70	80	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
9)	Alawalpur	Not Applicable due to no sewerage connection																	
10)	Mahetpur	Not Applicable due to no sewerage connection																	
11)	Begowal	90	100	60	90	80	100	80	100	70	100	0	10	80	95	10	40	40	60
12)	Mahilpur	Not Applicable due to no sewerage connection																	
13)	Bhulath	80	100	80	100	60	80	70	100	70	100	0	10	70	80	0	30	0	50
14)	Mukerian	90	95	80	100	80	100	80	90	80	90	15	40	80	90	45	50	70	90
15)	Rahon	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
16)	Nur mahal	20	40	15	25	10	70	10	60	0	90	0	10	40	90	20	30	40	50

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
17)	Shahkot	0	0	40	50	0	0	0	0	0	0	0	0	60	80	30	50	60	80
18)	Bhogpur	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
19)	Garhshankar	20	60	40	70	40	60	30	60	65	80	0	20	80	80	30	40	50	70
20)	Goraya	45	50	50	60	10	10	--	--	--	--	--	--	--	--	--	--	--	--
21)	Sultanpur lodhi	90	92	85	85	80	100	100	100	100	100	10	15	75	80	40	100	50	100
22)	Adampur	60	100	70	75	0	0	0	0	75	80	0	0	80	85	30	35	40	45
23)	Banga	95	98	95	98	95	98	100	100	100	100	0	15	70	80	60	85	85	90
24)	Balachaur	0	0	30	50	0	0	0	0	0	0	0	0	0	0	0	0	0	0
25)	Dasuya	100	100	100	100	90	100	100	100	100	100	10	20	80	100	40	60	90	100
26)	Urmur tanda	95	100	85	90	95	100	70	75	80	85	0	10	80	90	20	40	60	80
27)	Kartarpur	85	90	90	100	90	100	0	0	0	0	90	95	90	95	90	95	90	95
28)	Nawanshahr	100	100	90	100	90	95	100	100	100	100	10	15	80	80	40	50	60	65
29)	Nakodar	65	80	48	60	65	80	100	100	100	100	10	20	72	80	50	65	50	60

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
30)	Phillaur	50	80	95	100	95	100	95	100	70	70	5	30	100	100	75	80	80	80
31)	Kapurthala	90	100	90	100	85	90	90	100	80	100	5	20	75	80	90	95	85	90
		DDR Ludhiana																	
1.	Kiratpur Sahib	80	90	50	80	0	0	0	0	0	0	0	0	70	80	20	40	30	50
2.	Payal	65	75	75	80	65	70	75	80	75	85	30	40	90	90	0	0	0	0
3.	Amloh	70	90	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
4.	Morinda	98	100	35	50	80	100	0	80	0	100	0	20	75	80	40	60	92	100
5.	Sirhind Fatehgarh Sahib	90	100	40	100	70	100	0	50	0	100	0	10	50	80	25	50	70	90
6.	Ropar	95	100	80	90	90	100	85	100	85	100	20	30	80	90	60	80	60	80
7.	Bassi pathana	80	100	50	80	0	50	0	50	0	100	0	10	50	70	0	50	0	80
8.	Anandpur sahib	80	90	50	70	40	80	50	80	50	90	0	5	60	80	10	30	20	40
9.	Maloud	100	100	100	100	100	100	80	100	90	100	10	20	80	90	50	70	80	90
10.	Chamkaur Sahib	85	95	75	95	65	95	95	100	95	100	10	10	90	100	35	45	55	75
11.	Khamano	95	100	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
12.	Mullanpur	0	0	85	100	85	100	0	0	0	0	0	0	90	100	66	80	90	100
13.	Nangal	90	95	90	95	70	85	90	95	90	95	15	17	70	75	70	80	70	80
14.	Sahnewal	80	90	0	80	0	90	50	100	0	100	0	10	0	80	0	30	0	60
15.	Machhiwara	100	100	90	100	90	100	100	100	100	100	40	50	85	90	70	80	70	80
16.	Raikot	70	75	95	95	0	0	0	0	0	0	0	0	80	80	30	35	60	65
17.	Doraha	90	100	80	100	80	100	80	100	75	100	25	---	75	100	75	85	80	90
18.	Samrala	100	100	35	90	80	90	0	80	0	80	0	80	100	100	25	30	85	90
19.	Jagraon	80	100	85	100	65	100	80	100	80	100	0	10	70	80	20	40	65	70
20.	Mandi Gobindgarh	71	100	80	100	80	100	70	100	85	100			70	80	80	100	51	90
21.	Khanna	80	100	50	100	50	95	60	100	80	100	0	10	70	80	35	55	50	60
		DDR Patiala																	
1)	Amargarh	20	40	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
2)	Dirba	NA	20	20	50	100	100	0	0	0	100	0	20	80	80	0	80	0	80

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
3)	Ghanaur	90	100	95	100	80	100	0	100	0	100	0	20	80	80	15	50	75	90
4)	Bhadson	80	95	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
5)	Ghagga	10	35	0	35	0	0	0	0	0	0	0	0	50	75	30	50	50	70
6)	Handiaya	NA	80	1	100	0	0	0	0	0	0	0	0	100	100	1	100	8	90
7)	Cheema	NA	95	70	90	90	100	0	0	0	100	0	20	80	80	0	80	0	80
8)	Khanauri	NA	95	98	100	100	100	90	100	100	100	0	20	10	80	0	80	0	80
9)	Longowal	NA	90	80	90	0	60	0	0	0	100	0	0	80	90	15	50	15	40
10)	Moonak	20	50	30	50	70	90	90	100	90	100	0	10	0	70	0	20	0	50
11)	Sanaur	85	90	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE	NE
12)	Bhadaur	NA	85	9	100	0	0	0	0	0	0	0	0	100	100	17	100	59	90
13)	Bhawanigarh	50	60	30	60	0	0	0	0	0	0	0	0	60	80	0	30	0	40
14)	Lehragaga	80	90	50	80	50	80	0	100	0	80	0	0	60	70	0	40	0	70
15)	Patran	80	100	80	100	80	100	90	100	90	95	0	10	70	80	30	40	50	70
16)	Dhanaul	60	70	50	60	0	0	0	0	0	0	0	0	60	70	30	40	40	70

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
17)	Kurali	50	80	80	90	50	90	80	100	80	100	0	0	60	80	20	40	30	50
18)	Tapa	30	80	40	100	0	0	0	0	0	0	0	0	30	70	15	30	25	50
19)	Ahmedgarh	50	60	88	90	0	0	0	0	0	0	0	0	80	80	20	40	30	60
20)	Lalru	40	60	25	70	0	0	0	0	0	0	0	0	60	80	0	30	0	60
21)	Samana	80	100	90	100	95	100	100	100	100	100	5	20	80	80	60	80	85	90
22)	Banur	50	100	80	90	80	100	80	100	90	100	0	10	75	80	0	30	0	40
23)	Dhuri	NA	90	25	100	0	100	0	100	0	100	0	100	94	100	84	100	84	100
24)	Derabassi	70	75	85	95	0	60	0	100	0	70	0	0	60	80	50	60	70	80
25)	Naya gaon	10	50	10	75	0	0	0	0	0	0	0	0	50	70	30	40	50	60
26)	Sunam	50	80	80	90	0	80	0	80	0	100	0	10	70	80	0	30	20	60
27)	Nabha	15	25	35	50	0	0	0	0	0	0	0	0	75	80	30	50	30	70
28)	Sangrur	NA	85	60	100	0	85	0	100	0	0	0	0	80	90	70	85	50	80
29)	Zirakpur	50	100	90	100	80	100	60	100	100	100	0	5	70	80	30	40	45	70
30)	Rajpura	98	100	98	100	85	100	80	100	80	100	0	20	80	85	80	90	80	90

				Sewerage Management Indicators															
		Coverage of toilets		Coverage of sewage network services		Collection efficiency of the sewage network		Adequacy of sewage treatment capacity		Quality of sewage treatment		Extent of reuse and recycling of treated sewage		Efficiency in redressal of customer complaints		Extent of cost recovery in sewage management		Efficiency in collection of sewage charges	
	Formula	(FC / XM) x100		(FD / XM) x 100		(FZ / FW) x 100		(GB / FW) x 100		(GF / GE) x 100		(GD / FY) x 100		(GH / GG) x 100		(GU / GP) x 100		(GW / GU) x 100	
	Benchmark	100%		100%		100%		100%		100%		20%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
31)	Barnala	NA	85	53	100	0	100	0	100	0	100	0	20	100	100	38	100	58	90
32)	Kharar	50	100	60	90	70	80	0	80	0	90	0	10	70	80	30	45	60	70
33)	Malerkotla	68	80	79	90	0	0	0	0	0	0	0	0	70	80	25	50	55	70

				Water Supply Indicators															
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
1.	Amritsar (MC)	80	100	135	135	20	25	25	20	13	22	100	100	100	100	20	55	70	90
2.	Phagwara (MC)	85	100	135	135	50	80	30	20	12	12	100	100	75	90	95	100	90	95
3.	Hoshiarpur (MC)	90	100	135	135	25	60	30	20	10	12	100	100	100	100	70	80	70	75
4.	Moga (MC)	80	90	135	135	40	50	30	20	10	12	80	90	99	100	70	80	71	90
5.	Pathankot (MC)	95	100	145	150	0	0	30	20	12	12	100	100	90	100	146	150	61	80
6.	Bathinda (MC)	80	100	135	135	10	50	25	20	8	12	100	100	100	100	70	80	60	90
7.	Mohali (MC)	95	100	200	135	80	90	25	20	12	16	80	100	85	90	70	45	85	90
8.	Patiala (MC)	80	90	130	135	45	50	30	20	12	16	100	100	80	80	100	100	85	90
9.	Jalandhar (MC)	80	90	175	135	50	80	30	20	10	12	90	92	70	75	70	80	80	90
10.	Ludhiana (MC)	80	90	175	135	25	35	30	20	10	12	100	100	80	80	70	80	84	90
				DDR Amritsar															
21)	Ramdass	90	95	135	135	0	0	35	25	10	10	100	100	90	100	75	90	60	80
22)	Dera Baba Nanak	90	95	95	125	0	30	25	20	8	9	70	85	100	100	70	85	70	75
23)	Dhariwal	80	90	145	145	0	0	22	20	8	8	100	100	71	79	74	85	77	86

				Water Supply Indicators																	
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
24)	Rayya	80	90	130	135	0	0	30	20	10	10	100	100	70	80	70	90	90	90
25)	Shri Hargobindpur	75	85	200	135	0	0	33	20	8	8	100	100	75	80	83	90	83	90
26)	Majitha	95	98	135	135	0	0	30	20	10	10	100	100	90	100	70	80	50	80
27)	Quadian	80	90	160	135	0	0	25	20	8	8	100	100	75	80	80	90	80	90
28)	Raja Sansi	85	95	95	100	0	25	25	20	8	9	70	80	60	65	75	80	65	70
29)	Dina Nagar	85	95	125	135	0	0	20	20	10	10	100	100	90	100	85	90	80	90
30)	Bhikhiwind	85	95	90	100	0	0	25	20	8	8	100	100	100	100	70	80	70	80
31)	Fatehgarh Churian	80	90	145	135	0	0	25	20	8	8	100	100	72	80	75	80	72	90
32)	Khemkaran	90	95	135	135	0	0	27	20	10	10	100	100	90	100	70	80	60	80
33)	Ajnala	95	98	135	135	0	0	27	20	16	16	100	100	90	100	80	90	70	80
34)	Jandiala guru	95	98	135	135	0	0	25	20	10	10	100	100	90	100	85	90	70	90
35)	Sujanpur	95	100	100	100	0	0	25	20	8	8	100	100	80	100	80	90	90	100
36)	Patti	90	100	100	135	0	60	25	20	10	12	100	100	70	80	75	100	70	90
37)	Tarn Taran	85	100	100	135	0	40	25	20	12	12	100	100	70	80	75	80	70	80
38)	Gurdaspur	90	95	95	125	0	30	25	20	8	9	70	85	100	100	70	85	70	75

				Water Supply Indicators															
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
39)	Batala	85	95	150	135	0	0	25	20	10	10	100	100	70	80	70	85	70	70
40)	Narot Jamal Singh	70	80	100	135	0	0	30	20	10	10	80	100	70	90	70	90	70	75
				DDR Bathinda															
1)	Boha	70	85	70	70	0	25	30	20	6	8	100	100	70	85	65	70	70	80
2)	Rampura	70	80	70	100	0	20	35	20	4	6	100	100	75	75	70	85	60	70
3)	Ballianwali	70	80	100	120	0	20	35	20	4	6	70	80	70	75	70	80	60	70
4)	Chauke	70	80	100	110	0	25	35	20	4	6	70	80	70	80	70	85	60	70
5)	Maluka	70	80	70	100	0	0	30	20	4	6	100	100	80	80	70	70	75	80
6)	Nathana	70	80	70	100	0	0	30	20	4	6	100	100	80	80	70	80	60	70
7)	Lehra mohabbat	70	80	100	110	0	30	30	20	5	7	70	90	70	80	70	85	70	80
8)	Bariwala	85	95	135	135	0	0	25	20	12	16	80	90	80	90	75	75	60	70
9)	Kotha guru	70	85	70	100	0	0	30	20	4	6	70	75	75	80	70	85	70	75
10)	Kot Shamir	70	80	100	110	0	30	30	20	4	6	70	90	70	80	70	85	70	75
11)	Sangat mandi	75	85	135	135	--	--	23	20	12	16	100	100	76	85	70	80	70	75
12)	Bhai rupa	70	100	70	100	0	0	30	20	4	6	100	100	75	80	70	80	70	75

				Water Supply Indicators																	
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
13)	Joga	70	80	100	120	0	40	30	20	4	6	70	80	70	80	70	80	70	80
14)	Kotfatta	75	85	135	135	0	0	25	20	8	8	80	90	70	80	70	80	70	80
15)	Mandi kalan	70	85	110	120	0	25	30	20	4	8	70	80	70	80	70	85	70	80
16)	Mehraj	70	75	70	100	0	20	30	20	4	4	100	100	80	80	70	85	70	80
17)	Bhagta bhai ka	70	80	100	110	0	30	30	20	5	8	70	90	70	90	70	80	70	85
18)	Bhucho mandi	85	95	135	135	No	No	20	15	8	10	80	90	70	75	55	60	70	85
19)	Bareta	70	80	135	135	0	70	30	20	5	08	100	100	75	80	65	80	70	90
20)	Raman	72	80	135	135	--	--	25	20	15	17	100	100	70	85	65	75	73	75
21)	Bhikhi	38	70	135	135	8	70	30	20	3	5	100	100	75	80	70	90	72	90
22)	Goniana	90	95	135	135	No	No	25	20	8	10	80	90	80	80	70	80	70	80
23)	Gidderbaha	80	95	135	135	No	No	25	20	18	20	75	85	70	75	55	70	70	80
24)	Rampura phul	80	85	135	135	0	20	35	20	6	7	100	100	80	80	70	85	70	80
25)	Sardulgarh	80	85	135	135	0	40	25	20	5	10	100	100	72	80	65	70	72	80
26)	Maur	75	85	135	135	--	--	25	20	15	16	100	100	80	85	75	80	75	80
27)	Budhlada	75	90	135	135	3	30	25	20	6	8	100	100	73	80	75	80	75	80
28)	Talwandi saboo	75	100	135	135	0	40	30	20	4	8	100	100	70	80	70	80	70	80

				Water Supply Indicators															
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
29)	Malout	80	95	135	135	No	No	30	25	18	20	80	90	70	75	70	85	70	75
30)	Muktsar sahib	80	85	74	100	0	20	30	20	5	6	80	95	70	80	70	80	60	75
31)	Mansa	75	90	135	135	0	30	25	20	10	12	100	100	72	80	80	90	72	80
				DDR Ferozepur															
1)	Arniwala shek subhan	70	80	135	135	0	40	35	20	4	4	100	100	60	80	80	90	70	85
2)	Kot isse khan	90	100	135	135	20	50	30	20	8	10	100	100	80	80	83	86	70	90
3)	Mallanwala khas	70	95	135	135	0	0	35	20	9	12	100	100	80	90	75	90	85	95
4)	Mamdot	70	80	90	135	0	20	35	20	6	8	100	100	40	80	70	80	70	80
5)	Mudki	70	80	90	135	0	25	30	20	6	10	100	100	40	80	70	80	70	75
6)	Nihal Singh wala	70	80	80	135	0	50	30	20	6	8	100	100	40	80	70	90	70	80
7)	Guru harsahai	80	85	135	135	0	20	30	20	12	12	100	100	80	80	70	90	70	70
8)	Talwandi bhai	80	90	135	135	-	-	30	20	8	8	80	90	70	80	70	80	70	80
9)	Makhu	90	95	135	135	0	25	30	20	8	8	100	100	70	75	70	85	75	80
10)	Badhnikalan	75	85	135	135	-	-	30	20	4	6	80	90	70	80	70	85	70	75
11)	Dharamkot	90	100	135	135	20	45	30	20	10	10	100	100	60	75	70	80	60	80

				Water Supply Indicators															
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
12)	Baghapurana	100	100	135	135	10	20	30	20	10	10	100	100	100	100	70	80	60	90
13)	Jaitu	80	90	135	135	-	-	28	20	10	16	90	95	80	95	65	80	70	80
14)	Jalalabad	85	100	135	135	0	10	30	20	10	10	100	100	80	90	70	80	70	80
15)	Zira	90	95	135	135	0	20	30	20	8	10	100	100	70	90	70	80	70	75
16)	Abohar	85	100	75	135	0	100	30	25	8	12	100	100	80	80	60	80	60	70
17)	Faridkot	100	100	135	135	10	20	30	20	10	10	100	100	80	100	70	80	70	75
18)	Fazilka	80	90	135	135	0	30	30	20	10	10	100	100	70	80	70	80	60	70
19)	Kotkapura	80	90	135	135	-	-	25	20	10	16	80	90	75	85	70	75	70	80
20)	Ferozepur	90	100	135	135	0	0	30	20	12	16	100	100	80	90	72	75	96	100
21)	Fatehgarh Panjtoor	80	90	135	135	0	40	30	20	4	4	100	100	60	80	70	80	70	85
				DDR Jalandhar															
1)	Talwara	80	90	135	135	0	0	20	20	10	14	100	100	95	100	85	95	85	90
2)	Gardhiwala	100	100	135	135	0	20	30	20	10	12	100	100	80	90	70	80	60	80
3)	Shamchurasi	100	100	135	135	0	30	30	20	10	10	100	100	80	90	60	70	60	70
4)	Bilga	80	100	135	135	0	20	30	20	8	8	100	100	70	80	60	65	60	65
5)	Hariana	100	100	135	135	0	20	30	20	8	8	100	100	80	80	60	70	60	70

				Water Supply Indicators																	
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
6)	Nadala	70	100	100	135	0	30	30	20	4	8	100	100	70	90	55	65	55	65
7)	Dhilwan	70	90	135	135	0	30	30	20	6	8	100	100	65	80	65	70	65	70
8)	Lohian khas	70	80	135	135	0	20	30	20	4	4	80	100	70	80	60	65	60	65
9)	Alawalpur	80	95	135	135	0	15	30	20	8	10	100	100	80	100	60	70	60	70
10)	Mahetpur	80	85	135	135	0	20	30	20	4	6	100	100	50	65	60	70	60	70
11)	Begowal	80	85	135	135	0	30	30	20	6	6	100	100	70	85	60	65	60	65
12)	Mahilpur	90	100	135	135	20	30	30	20	12	12	100	100	80	80	60	70	60	70
13)	Bhulath	80	100	135	135	0	20	30	20	8	10	100	100	80	90	60	70	60	70
14)	Mukerian	100	100	135	135	0	30	30	20	10	12	100	100	80	80	60	65	60	65
15)	Rahon	100	100	135	135	0	30	30	20	12	12	100	100	80	80	70	75	70	75
16)	Nurmahal	70	80	135	35	0	20	30	20	10	12	100	100	80	90	70	75	70	75
17)	Shahkot	75	80	135	135	0	20	30	20	6	8	100	100	80	100	70	80	60	70
18)	Bhogpur	100	100	135	135	100	100	30	20	8	10	100	100	100	100	78	100	87	100
19)	Garhshankar	90	100	135	135	0	20	30	20	10	10	100	100	80	80	70	80	75	85
20)	Goraya	97	98	135	135	100	100	29	20	10	10	100	100	80	100	70	80	70	75
21)	Sultanpur lodhi	90	95	135	135	10	30	30	20	10	12	100	100	70	80	70	80	70	85

				Water Supply Indicators															
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
22)	Adampur	80	90	135	135	0	25	30	20	10	12	100	100	80	100	70	80	70	80
23)	Banga	95	98	135	135	0	15	30	20	10	12	100	100	75	80	70	92	65	75
24)	Balachaur	80	95	135	135	0	10	25	20	10	10	100	100	80	100	70	85	85	90
25)	Dasuya	100	100	135	135	20	20	20	20	10	12	100	100	100	100	70	80	90	100
26)	Urmur tanda	95	100	135	135	0	20	30	20	8	8	100	100	90	100	75	80	85	90
27)	Kartarpur	80	85	135	135	0	20	30	20	8	10	100	100	80	85	70	80	70	75
28)	Nawanshahr	90	90	135	135	0	15	30	20	10	12	100	100	80	90	70	85	60	70
29)	Nakodar	92	100	135	135	0	0	28	25	8	8	100	100	77	80	60	65	60	70
30)	Phillaur	97	100	135	135	0	0	20	18	10	10	100	100	100	100	80	80	80	80
31)	Kapurthala	90	95	135	135	55	60	15	10	12	12	100	100	75	80	95	100	85	90
		DDR Ludhiana																	
1.	Kiratpur Sahib	100	100	70	135	0	20	30	20	3	6	100	100	100	100	85	100	95	100
2.	Payal	80	90	135	135	0	0	16	10	10	24	100	100	80	80	80	100	80	90
3.	Amloh	80	100	135	135	0	20	30	20	10	10	100	100	90	100	70	85	60	78
4.	Morinda	90	100	140	135	0	30	25	20	12	18	100	100	75	80	65	80	85	90

				Water Supply Indicators															
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
5.	Sirhind Fatehgarh Sahib	95	100	135	135	0	30	25	20	12	18	100	100	80	80	70	80	80	90
6.	Ropar	100	100	150	135	0	20	20	10	16	16	100	100	90	100	70	90	70	90
7.	Bassi pathana	90	100	135	135	0	30	22	20	12	18	100	100	80	80	65	85	80	90
8.	Anandpur sahib	100	100	100	100	10	20	20	18	10	10	100	100	70	80	80	85	60	70
9.	Maloud	70	80	135	135	0	0	26	20	10	24	100	100	80	80	60	80	80	90
10.	Chamkaur Sahib	70	75	90	100	0	0	30	20	8	10	90	100	80	80	60	80	80	90
11.	Khamano	85	95	90	90	20	30	15	10	7	8	100	100	80	80	80	85	80	85
12.	Mullanpur	84	100	135	135	0	0	16	10	10	12	80	100	90	100	66	80	90	100
13.	Nangal	90	95	90	95	70	75	15	10	16	16	90	95	80	90	80	90	70	80
14.	Sahnewal	80	90	90	100	0	20	30	20	8	12	85	95	80	90	70	85	70	85
15.	Machhiwara	80	90	135	135	0	0	26	20	10	24	100	100	80	80	70	100	80	90
16.	Raikot	85	90	100	100	20	25	30	20	7	7	85	90	95	100	60	65	60	65
17.	Doraha	85	100	75	100	0	0	30	20	8	10	100	100	70	80	80	60	80	100
18.	Samrala	85	100	135	135	0	20	28	25	6	10	100	100	80	80	65	80	85	90

				Water Supply Indicators															
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
19.	Jagraon	80	100	135	135	0	15	30	20	12	12	100	100	80	80	70	85	65	70
20.	Mandi Gobindgarh	85	100	135	135	1	100	20	20	14	16	80	100	70	80	75	100	52	90
21.	Khanna	80	100	67	135	20	60	40	20	10	12	85	100	85	80	70	80	65	90
		DDR Patiala																	
1)	Amargarh	80	100	70	135	0	20	30	20	6	10	100	100	80	85	70	85	70	80
2)	Dirba	80	100	135	135	0	0	20	20	10	12	100	100	80	80	71	80	71	80
3)	Ghanaur	80	100	135	135	0	50	22	20	16	20	100	100	80	80	60	80	75	90
4)	Bhadson	85	100	135	135	0	10	30	20	8	10	100	100	70	80	70	80	70	85
5)	Ghagga	90	100	135	135	0	10	30	20	8	10	100	100	80	85	70	80	65	75
6)	Handiaya	85	100	135	135	0	0	25	20	10	12	100	100	100	100	100	100	76	100
7)	Cheema	80	90	135	135	0	100	27	20	10	14	100	100	80	90	71	80	68	90
8)	Khanauri	93	100	135	135	0	0	25	20	10	14	100	100	80	90	75	90	90	95
9)	Longowal	80	90	135	135	0	0	20	20	8	10	100	100	80	90	75	100	70	90
10)	Moonak	80	100	135	135	0	20	30	20	10	14	100	100	82	90	75	80	50	60
11)	Sanaur	80	95	135	135	0	10	30	20	10	14	100	100	70	80	70	80	60	70

				Water Supply Indicators															
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
12)	Bhadaur	83	100	135	135	0	0	25	10	10	12	100	100	100	100	68	100	62	90
13)	Bhawanigarh	80	100	135	135	10	30	30	20	10	16	100	100	100	100	70	85	50	60
14)	Lehragaga	80	90	0	80	0	25	30	20	0	10	0	30	0	70	70	80	60	70
15)	Patran	90	100	135	135	0	30	30	20	13	14	100	100	80	80	70	85	60	70
16)	Dhanaul	90	100	135	135	10	20	30	20	10	14	100	100	80	90	70	80	70	75
17)	Kurali	80	100	135	135	0	10	30	20	13	14	100	100	75	80	70	85	50	60
18)	Tapa	80	90	135	135	10	20	30	20	10	16	100	100	70	75	70	85	55	65
19)	Ahmedgarh	80	100	135	135	0	10	30	20	10	16	100	100	80	100	70	80	60	70
20)	Lalru	80	100	135	135	0	10	30	20	10	14	100	100	75	80	70	80	50	60
21)	Samana	90	100	150	135	0	30	25	20	12	18	100	100	80	80	70	80	80	90
22)	Banur	80	100	135	135	0	10	30	20	14	16	100	100	75	80	70	80	50	60
23)	Dhuri	80	100	135	135	0	0	20	10	10	12	100	100	97	100	63	100	68	100
24)	Derabassi	95	100	135	135	0	25	30	20	17	20	100	100	70	80	75	80	60	70
25)	Naya gaon	90	100	135	135	0	10	30	20	15	16	100	100	75	80	70	80	70	85
26)	Sunam	70	100	135	135	0	10	30	20	12	16	100	100	100	100	65	75	70	85
27)	Nabha	75	90	135	135	0	10	30	20	12	12	100	100	80	100	60	70	70	80

				Water Supply Indicators															
		Coverage of water supply Connections		Per capita supply of water		Extent of metering of water connections		Extent of non revenue water		Continuity of water supply		Quality of water supplied		Efficiency in redressal of customer complaints		Cost recovery in water supply services		Efficiency in collection of water supply- related charges	
	Benchmark	100%		135 lpcd		100%		20%		24 hours		100%		80%		100%		90%	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
28)	Sangrur	75	100	135	135	0	0	15	10	10	10	100	100	80	100	75	100	75	80
29)	Zirakpur	80	100	135	135	0	20	30	20	14	16	100	100	75	80	80	90	80	85
30)	Rajpura	80	100	140	135	0	50	25	20	8	12	100	100	73	80	78	100	79	90
31)	Barnala	84	100	135	135	15	50	18	10	14	14	100	100	100	100	80	100	71	90
32)	Kharar	80	100	135	135	0	10	30	20	12	16	100	100	70	80	70	80	70	80
33)	Malerkotla	78	100	110	125	20	25	30	20	14	16	80	90	80	80	70	80	70	80

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
1.	Amritsar (MC)	12	20	20	10
2.	Phagwara (MC)	02	03	30	10
3.	Hoshiarpur (MC)	21	35	30	10
4.	Moga (MC)	0	15	20	10
5.	Pathankot (MC)	20	40	20	10
6.	Bathinda (MC)	30	40	15	10
7.	Mohali (MC)	35	40	18	10
8.	Patiala (MC)	10	20	15	10
9.	Jalandhar (MC)	15	30	13	09
10.	Ludhiana (MC)	20	25	25	15
		DDR Amritsar			
1)	Ramdass	NIL	NIL	NIL	NIL
2)	Dera baba nanak	NIL	NIL	NIL	NIL
3)	Dhariwal	NIL	NIL	NIL	NIL
4)	Rayya	NIL	NIL	NIL	NIL
5)	Shri Hargobind pur	NIL	NIL	NIL	NIL
6)	Majitha	NIL	NIL	NIL	NIL
7)	Quadian	NIL	NIL	NIL	NIL
8)	Raja Sansi	NIL	NIL	NIL	NIL

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
9)	Dina nagar	NIL	NIL	NIL	NIL
10)	Bhikhiwind	NIL	NIL	NIL	NIL
11)	Fatehgarh churian	NIL	NIL	NIL	NIL
12)	Khemkaran	NIL	NIL	NIL	NIL
13)	Ajnala	NIL	NIL	NIL	NIL
14)	Jandiala guru	NIL	NIL	NIL	NIL
15)	Sujanpur	NIL	NIL	NIL	NIL
16)	Patti	NIL	NIL	NIL	NIL
17)	Tarn taran	NIL	NIL	NIL	NIL
18)	Gurdaspur	NIL	NIL	NIL	NIL
19)	Batala	NIL	NIL	NIL	NIL
20)	Narot Jamal Singh	NIL	NIL	NIL	NIL
		DDR Bathinda			
1)	Boha	NIL	NIL	NIL	NIL
2)	Rampura	NIL	NIL	NIL	NIL
3)	Ballianwali	NIL	NIL	NIL	NIL
4)	Chauke	NIL	NIL	NIL	NIL
5)	Maluka	NIL	NIL	NIL	NIL

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
6)	Nathana	NIL	NIL	NIL	NIL
7)	Lehra mohabbat	NIL	NIL	NIL	NIL
8)	Bariwala	NIL	NIL	NIL	NIL
9)	Kotha guru	NIL	NIL	NIL	NIL
10)	Kot Shamir	NIL	NIL	NIL	NIL
11)	Sangat mandi	NIL	NIL	NIL	NIL
12)	Bhai rupa	NIL	NIL	NIL	NIL
13)	Joga	NIL	NIL	NIL	NIL
14)	Kotfatta	NIL	NIL	NIL	NIL
15)	Mandi kalan	NIL	NIL	NIL	NIL
16)	Mehraj	NIL	NIL	NIL	NIL
17)	Bhagta bhai ka	NIL	NIL	NIL	NIL
18)	Bhucho mandi	NIL	NIL	NIL	NIL
19)	Bareta	NIL	NIL	NIL	NIL
20)	Raman	NIL	NIL	NIL	NIL
21)	Bhikhi	NIL	NIL	NIL	NIL
22)	Goniana	NIL	NIL	NIL	NIL
23)	Gidderbaha	NIL	NIL	NIL	NIL

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
24)	Rampura phul	NIL	NIL	NIL	NIL
25)	Sardulgarh	NIL	NIL	NIL	NIL
26)	Maur	NIL	NIL	NIL	NIL
27)	Budhlada	NIL	NIL	NIL	NIL
28)	Talwandi saboo	NIL	NIL	NIL	NIL
29)	Malout	NIL	NIL	NIL	NIL
30)	Muktsar sahib	NIL	NIL	NIL	NIL
31)	Mansa	NIL	NIL	NIL	NIL
		DDR Ferozpur			
1)	Arniwalasheksubhan	NIL	NIL	NIL	NIL
2)	Kotisse khan	NIL	NIL	NIL	NIL
3)	Mallanwalakhas	NIL	NIL	NIL	NIL
4)	Mamdot	NIL	NIL	NIL	NIL
5)	Mudki	NIL	NIL	NIL	NIL
6)	Nihalsinghwala	NIL	NIL	NIL	NIL
7)	Guru har sahai	NIL	NIL	NIL	NIL
8)	Talwandibhai	NIL	NIL	NIL	NIL
9)	Makhu	NIL	NIL	NIL	NIL

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
10)	Badhnikalan	NIL	NIL	NIL	NIL
11)	Dharamkot	NIL	NIL	NIL	NIL
12)	Baghapuran	NIL	NIL	NIL	NIL
13)	Jaitu	NIL	NIL	NIL	NIL
14)	Jalalabad	NIL	NIL	NIL	NIL
15)	Zira	NIL	NIL	NIL	NIL
16)	Abohar	NIL	NIL	NIL	NIL
17)	Faridkot	NIL	NIL	NIL	NIL
18)	Fazilka	NIL	NIL	NIL	NIL
19)	Kotkapura	NIL	NIL	NIL	NIL
20)	Ferozepur	NIL	NIL	NIL	NIL
21)	Fatehgarh Panjtoor	NIL	NIL	NIL	NIL
		DDR Jalandhar			
1)	Talwara	NIL	NIL	NIL	NIL
2)	Gardhiwala	NIL	NIL	NIL	NIL
3)	Shamchurasi	NIL	NIL	NIL	NIL
4)	Bilga	NIL	NIL	NIL	NIL
5)	Hariana	NIL	NIL	NIL	NIL
6)	Nadala	NIL	NIL	NIL	NIL

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
7)	Dhilwan	NIL	NIL	NIL	NIL
8)	Lohian khas	NIL	NIL	NIL	NIL
9)	Alawalpur	NIL	NIL	NIL	NIL
10)	Mahetpur	NIL	NIL	NIL	NIL
11)	Begowal	NIL	NIL	NIL	NIL
12)	Mahilpur	NIL	NIL	NIL	NIL
13)	Bhulath	NIL	NIL	NIL	NIL
14)	Mukerian	NIL	NIL	NIL	NIL
15)	Rahon	NIL	NIL	NIL	NIL
16)	Nur mahal	NIL	NIL	NIL	NIL
17)	Shahkot	NIL	NIL	NIL	NIL
18)	Bhogpur	NIL	NIL	NIL	NIL
19)	Garhshankar	NIL	NIL	NIL	NIL
20)	Goraya	NIL	NIL	NIL	NIL
21)	Sultanpur lodhi	NIL	NIL	NIL	NIL
22)	Adampur	NIL	NIL	NIL	NIL
23)	Banga	NIL	NIL	NIL	NIL
24)	Balachaur	NIL	NIL	NIL	NIL
25)	Dasuya	NIL	NIL	NIL	NIL

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
26)	Urmur tanda	NIL	NIL	NIL	NIL
27)	Kartarpur	NIL	NIL	NIL	NIL
28)	Nawanshahr	NIL	NIL	NIL	NIL
29)	Nakodar	NIL	NIL	NIL	NIL
30)	Phillaur	NIL	NIL	NIL	NIL
31)	Kapurthala	NIL	NIL	NIL	NIL
	DDR Ludhiana				
1.	Kiratpur Sahib	NIL	NIL	NIL	NIL
2.	Payal	NIL	NIL	NIL	NIL
3.	Amloh	NIL	NIL	NIL	NIL
4.	Morinda	NIL	NIL	NIL	NIL
5.	Sirhind Fatehgarh Sahib	NIL	NIL	NIL	NIL
6.	Ropar	NIL	NIL	NIL	NIL
7.	Bassi pathana	NIL	NIL	NIL	NIL
8.	Anandpur sahib	NIL	NIL	NIL	NIL
9.	Maloud	NIL	NIL	NIL	NIL
10.	Chamkaur Sahib	NIL	NIL	NIL	NIL
11.	Khamano	NIL	NIL	NIL	NIL
12.	Mullanpur	NIL	NIL	NIL	NIL

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
13.	Nangal	NIL	NIL	NIL	NIL
14.	Sahnewal	NIL	NIL	NIL	NIL
15.	Machhiwara	NIL	NIL	NIL	NIL
16.	Raikot	NIL	NIL	NIL	NIL
17.	Doraha	NIL	NIL	NIL	NIL
18.	Samrala	NIL	NIL	NIL	NIL
19.	Jagraon	NIL	NIL	NIL	NIL
20.	Mandi Gobindgarh	NIL	NIL	NIL	NIL
21.	Khanna	NIL	NIL	NIL	NIL
	DDR Patiala				
1)	Amargarh	NIL	NIL	NIL	NIL
2)	Dirba	NIL	NIL	NIL	NIL
3)	Ghanaur	NIL	NIL	NIL	NIL
4)	Bhadson	NIL	NIL	NIL	NIL
5)	Ghagga	NIL	NIL	NIL	NIL
6)	Handiaya	NIL	NIL	NIL	NIL
7)	Cheema	NIL	NIL	NIL	NIL
8)	Khanauri	NIL	NIL	NIL	NIL

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
9)	Longowal	NIL	NIL	NIL	NIL
10)	Moonak	NIL	NIL	NIL	NIL
11)	Sanaur	NIL	NIL	NIL	NIL
12)	Bhadaur	NIL	NIL	NIL	NIL
13)	Bhawanigarh	NIL	NIL	NIL	NIL
14)	Lehragaga	NIL	NIL	NIL	NIL
15)	Patran	NIL	NIL	NIL	NIL
16)	Dhanaul	NIL	NIL	NIL	NIL
17)	Kurali	NIL	NIL	NIL	NIL
18)	Tapa	NIL	NIL	NIL	NIL
19)	Ahmedgarh	NIL	NIL	NIL	NIL
20)	Lalru	NIL	NIL	NIL	NIL
21)	Samana	NIL	NIL	NIL	NIL
22)	Banur	NIL	NIL	NIL	NIL
23)	Dhuri	NIL	NIL	NIL	NIL
24)	Derabassi	NIL	NIL	NIL	NIL
25)	Naya gaon	NIL	NIL	NIL	NIL
26)	Sunam	NIL	NIL	NIL	NIL
27)	Nabha	NIL	NIL	NIL	NIL

		Storm Water Drainage Indicators			
	Benchmark	Coverage of storm water drainage network		Incidence of water logging/ flooding	
	Formula	(IE / ID) x 100		(IF x IG)	
		Current (2018-19)	Target (2019-20)	Current (2018-19)	Target (2019-20)
28)	Sangrur	NIL	NIL	NIL	NIL
29)	Zirakpur	NIL	NIL	NIL	NIL
30)	Rajpura	NIL	NIL	NIL	NIL
31)	Barnala	NIL	NIL	NIL	NIL
32)	Kharar	NIL	NIL	NIL	NIL
33)	Malerkotla	NIL	NIL	NIL	NIL

Dated, Chandigarh: 28.06.2019

M P SINGH, IAS,
Additional Chief Secretary, Government of Punjab,
Department of Local Government

Endst No. 5/177/2014(2011)-1lg4/ dated, Chandigarh,

A copy is forwarded to the Controller, Printing & Stationery, Punjab, Mohali, with the request to publish the notification in the Extraordinary Gazette of Punjab Government and Supply 50 spare copies of the same for the official use.

Under Secretary Local Government

Endst No. 5/177/2014(2011)-1lg4/ 1978-1987 dated, Chandigarh: 28.06.2019

A copy of each is forwarded to the following for information and necessary action:-

1. Secretary to the Government of India, Ministry of Urban Development, New Delhi.
2. Director, Local Government Punjab, Chandigarh.
3. Chief Executive Officer, Punjab Water Supply & Sewerage Board, Chandigarh.
4. Joint Deputy Director, Directorate Local Government.
5. All Chief Engineers, Local Government.
6. General Manager, PMIDC, Chandigarh
7. Deputy Controller (Finance & Accounts), Local Government Department, Punjab, Chandigarh.
8. Commissioners of all Municipal Corporation in the Sate.
9. All Regional Deputy Director of Local Government in the state.
10. Executive Officers of all Municipal Councils/Nagar Panchayats in the State.

Under Secretary Local Government

Scanned by CamScanner